

**City of Detroit**  
**Water and Sewerage Department**  
**Laboratory Analysis of Water Samples Collected at**  
**Lake Huron Plant**  
**June 13, 2006**

Parameter	Formula	Units	Raw	Tap	MCL	Sec.Std	MDL
Turbidity		NTU	0.90	0.06	0.3/95% (1)		
Total Solids		mg/l	145	137		500	10
Total Dissolved Solids		mg/l	126	140		500	10
Aluminum	Al	mg/l	0.117	0.107		0.05-0.2	0.005
Iron	Fe	mg/l	0.169	0.100		0.3	0.005
Copper	Cu	mg/l	0.013	0.006	1.3		0.002
Magnesium	Mg	mg/l	3.64	3.70			0.5
Calcium	Ca	mg/l	28.0	28.1			0.1
Sodium	Na	mg/l	4.43	4.66		20 (2)	0.1
Potassium	K	mg/l	0.93	0.93			0.1
Manganese	Mn	mg/l	0.008	0.005		0.05	0.002
Zinc	Zn	mg/l	<0.1	<0.1		5	0.1
Silica	SiO <sub>2</sub>	mg/l	7.4	13.1			0.4
Sulfate	SO <sub>4</sub>	mg/l	21.9	20.4			
Chloride	Cl <sup>-</sup>	mg/l	7.0	8.5		250	5
Phosphorus	P	mg/l	<0.05	0.27			0.05
Free Carbon Dioxide	CO <sub>2</sub>	mg/l	1.8	4.2			
Total Hardness (3), (4), (5)		mg/l	100	100			
Total Alkalinity (3)		mg/l	81	73			
Carbonate Alkalinity (3)		mg/l	0	0			
Bi-Carbonate Alkalinity (3)		mg/l	81	73			
Non-Carbonate Hardness (3)		mg/l	19	27			
Chemical Oxygen Demand		mg/l	<2.0	91.9			2
Dissolved Oxygen		mg/l	9.9	11.0			
Ammonia Nitrogen	NH <sub>3</sub> -N	mg/l	<0.1	<0.1			0.1
Organic Nitrogen		mg/l	0.4	0.2			0.1
Nitrite Nitrogen	NO <sub>2</sub> -N	mg/l	<0.1	<0.1	1		0.1
Nitrate Nitrogen	NO <sub>3</sub> -N	mg/l	0.40	0.42	10	10	0.1
Fluoride	F	mg/l	0.1	1.1	4		0.5
pH			7.95	7.54	6.5-8.5	6.5-8.5	
Specific Conductance @ 25 °C.		micromhos	220	230			
Temperature in °C.			17.1	18.2			

Legend	Notes:
MCL: Maximum Contaminant Level	(1) Turbidity must not exceed 0.3 NTU in 95% of daily samples in any month
Sec.Std: Secondary Standard	(2) EPA Guidance Level
NTU: Nephelometric Turbidity Unit	(3) As Calcium Carbonate
mg/l: Milligram Per Liter	mg/l is equivalent to part per million (ppm)
MDL: Method Detection Limit	(4) By Titration
<: Less than	(5) Tap Water Hardness in Grains per Gallon <span style="float: right;">5.80 GPG</span>
AE: Analytical Error	(6) Reported results are below the low calibration standard but above the instrument detection limit.
IV: Invalid Sample	

Analyst: Brian Brown

Reviewed By: Mary Lynn Semegan

Sr. Analytical Chemist

Principal Chemist

Initial

B. B.

Date: July 17, 2006

Initial

M.L.S.

Date: July 28, 2006

**Victor M. Mercado, Director**  
**Detroit Water & Sewerage Department**