

City of Detroit
Water and Sewerage Department
Laboratory Analysis of Water Samples Collected at
Southwest Plant
May 10, 2004

RECEIVED
 AUG 09 2004
 Y.C.U.A.

Parameter	Formula	Units	Raw	Tap	MCL	Sec.Std	MDL
Turbidity		NTU	8.70	0.09	0.3/95% (1)		
Total Solids		mg/l	199	188		500	10
Total Dissolved Solids		mg/l	155	163		500	10
Aluminum	Al	mg/l	0.657	0.102		0.05-0.2	0.005
Iron	Fe	mg/l	0.604	0.028		0.3	0.002
Copper	Cu	mg/l	0.019	0.012	1.3		0.001
Magnesium	Mg	mg/l	8.55	8.33			0.2
Calcium	Ca	mg/l	17.3	18.9			0.06
Sodium	Na	mg/l	5.02	4.88		20 (2)	0.01
Potassium	K	mg/l	1.35	1.11			0.01
Manganese	Mn	mg/l	0.013	0.001		0.05	0.001
Zinc	Zn	mg/l	<0.01	<0.01		5	0.01
Silica	SiO ₂	mg/l	12.26	16.32			0.4
Sulfate	SO ₄	mg/l	14.0	24.7			
Chloride	Cl ⁻	mg/l	10.0	11.4		250	1
Phosphorus	P	mg/l	<0.01	0.24			0.01
Free Carbon Dioxide	CO ₂	mg/l	0.9	4.3			
Total Hardness (3), (4), (5)		mg/l	115	114			
Total Alkalinity (3)		mg/l	83	82			
Carbonate Alkalinity (3)		mg/l	0	0			
Bi-Carbonate Alkalinity (3)		mg/l	83	82			
Non-Carbonate Hardness (3)		mg/l	32	32			
Chemical Oxygen Demand		mg/l	<2.0	4.0			2
Dissolved Oxygen		mg/l	11.3	10.9			
Ammonia Nitrogen	NH ₃ -N	mg/l	<0.10	<0.10			0.1
Organic Nitrogen		mg/l	0.3	0.2			0.1
Nitrite Nitrogen	NO ₂ -N	mg/l	<0.01	<0.01	1		0.01
Nitrate Nitrogen	NO ₃ -N	mg/l	0.64	0.63	10	10	0.01
Fluoride	F	mg/l	0.1	0.9	4		0.1
pH			7.98	7.58	6.5-8.5	6.5-8.5	
Specific Conductance @ 25 °C.		micromhos	202	212			
Temperature in °C.			14.3	13.2			

Legend	Notes:
MCL: Maximum Contaminant Level	(1) Turbidity must not exceed 0.3 NTU in 95% of daily samples in any month
Sec.Std: Secondary Standard	(2) EPA Guidance Level
NTU: Nephelometric Turbidity Unit	(3) As Calcium Carbonate
mg/l: Milligram Per Liter	mg/l is equivalent to part per million (ppm)
MDL: Method Detection Limit	(4) By Titration
<: Less than	(5) Tap Water Hardness in Grains per Gallon
EF: Equipment Failure	6.61 GPG
IV: Invalid Sample	

Analyst: Brian Brown

Sr. Analytical Chemist

Initial **B. B.**

Date: June 23, 2004

Reviewed By: Bahi Habib, P.E. Chemical Engineer

Initial **B. H.**

Date: June 24, 2004

Victor M. Mercado, Director
Detroit Water & Sewerage Department

Revised June, 2004